



Allowable Uses

- Permanent 240V Overhead and Customer Owned Underground.
- Temporary Overhead and Temporary Underground Service.
- Permanent 240V Underground PNM Service <100' Maximum or Less than (4/0 Underground Cable, NOT Approved for 350 Underground Cable)

NOTES

- (1) Socket to be Underwriters Laboratory (UL) listed.
- (2) Connections for terminating service conductors shall be the lay-in type.
- (3) Service conduit to enter at point "A"
- (4) Permanent 240V overhead, customer owned underground, permanent 240V underground PNM Service <100' Maximum or less than (4/0 underground cable), or overhead and underground temporary service only.
- (5) Meter shall be 4' 5' 6" from finished grade.
- (6) Commercial application for non-critical loads, i.e. sprinkler control and gates. PNM will allow socket without bypass handle.
- (7) PNM does not permit a trough ahead of meter socket.
- (8) Metering and instrument cabinets shall not be used to house Customer-owned equipment, such as distribution panels or other equipment, nor used as a junction box/trough for the distribution of circuits.
- (9) Customer building numbers must be permanently painted on proper meter panels.
- (10) 125A is only applicable for manufactured, mobile homes, temporary overhead and underground service and replacing existing 100A or less meter socket.
- (11) PNM does not permit a trough ahead of meter socket.

REFERENCES

- (1) See DS-4-6.0 120/240V Underground Temporary Service Pole
- (2) See DS-4-8.0 Overhead Permanent/Temporary Single-Phase or Temporary Three-Phase Service Pole
- (3) See DS-4-9.0 Underground Residential Customer-Owned Service
- (4) See DM-4-11.0 Maximum Available Fault Current
- (5) See MS-3-7.0 Over 320A 240V Single-Phase Meter Options

Approved Equipment		
Manufacturer	Item	Mfg Part#
Eaton	200A OH/UG Ringless w/Gasket	MB(***)w/ Gasket
Eaton	200A OH/UG Ringless 8T Socket	MBT48B200BTS
Eaton **	200A OH/UG Ringless	MB2040PV200BTS
Leviton	200A OH/UG Ringless 8T Socket	LP820-TMC
Milbank	200A OH/UG Ringless 4T Socket	U5168-XTL-200
Milbank	200A OH/UG Ringless Socket	U4801-XL-5T9
Milbank	200A OH/UG Ringless 20T Socket	U5268-XTL-200
Siemens	200A OH/UG Ringless 16T Socket	MC0816B1200RCT
Siemens	200A OH/UG Ringless 16T Socket	MC0816B1200JLT
Siemens	200A OH/UG Ringless 16T Socket	MC2040B1200R
Siemens	200A OH/UG Ringless 16T Socket	MC2040B1200JLC
Siemens	200A OH/UG Ringless 30T Socket	MC3040B1200R
	Residential ONLY	
Siemens	200A OH/UG Ringless 30T Socket	MC3042B1200RC
	Residential ONLY	
Siemens	200A OH/UG Ringless 40T Socket	MC2040B1200RC
Square D	Residential ONLY 200A OH/UG Ringless 8T Socket	RC816F200S
Square D	200A OH/UG Ringless 16T Socket	RC816F200C
Oquale D	Residential ONLY	NC010F200C
Square D	100A OH/UG Ringless 16T Socket	RC1624M100S
Square D	200A OH/UG Ringless 20T Socket	RC2040M200SS
Square D	200A OH/UG Ringless 20T Socket	RC2040M200S
Square D	200A OH/UG Ringless 30T Socket	RC3042M200PS
Square D	200A OH/UG Ringless 40T Socket	RC2040M200C

^{** 225}A buss makes solar tie ready, eliminating the need for supply side

For ease of checking service without interruption, PNM will no longer allow ring meter sockets as of 12/01/2013.

^{***} There are various catalog # available when gasket is included.