



NOTES

- (1) Supply cable (direct buried) shall not be installed within 5' horizontally of a swimming pool or its auxiliary equipment.
- (2) NESC Rule 351 C1
- (3) NEC Article 680-10

REFERENCES

- (1) See DS-13-6.0 Swimming Pool Clearances-Overhead