



NOTES

- (1) Guard post minimum 4" x 5' galvanized rigid steel conduit concrete filled.
- (2) 3000 PSI concrete base.

Guard Post