



NOTES

- (1) Where applicable, compaction in city or state right-of-way shall meet or exceed minimum requirements.
- (2) Shading and bedding material to be Type IV, Class 2 for cable in conduit. Type III material is suitable for either type of installation. Refer to DS-10-12.4 for fill material requirements.
- (3) If trench-run material meets backfill material type requirements, 3" bedding may be omitted provided the trench bottom is smooth, flat, and without surface irregularities.
- (4) For installation without the upper layer of cable, a minimum of 6" of shading over the primary cable is required.
- (5) Latest OSHA trench safety requirements must be strictly observed.
- (6) Warning tape shall be placed a minimum of 12" above the upper level of electrical cable at the center of the trench.
- (7) PNM owned or maintained streetlight circuits may be installed in trench next to electric cables.
- (8) Private area lighting or private streetlight circuits must maintain 12" separation from all other joint occupants.

REFERENCES

- (1) NESC rule 352, 353, 354