



NOTES

- (1) Supply cable (direct buried) shall not be installed within 5' horizontally of a swimming pool or its auxiliary equipment.
- (2) NESC Rule 234 and 351 C1
- (3) For NESC clearance purpose, spas (including whirlpools, hot-tubs, jacuzzis, or other similar installations not suitable for swimming) are not considered as swimming pools
- (4) NEC Article 680-10

REFERENCES

- (1) See DS-13-6.0 Swimming Pool Clearances-Overhead