



Important:

Socket shall be wired phase 1-2-3 from left to right and the conductors marked as such. Each conductor phase will be identified at the weather head or padmount, and at the meter base using band-wraps of electrical tape:

- One band for phase one
- Two bands for phase two
- Three bands for phase three
- White tape is suitable for neutral conductors only.

NOTES

- (1) Thirteen-terminal meter socket should be sent to PNM for pre-wiring.
- (2) Guard post are required in traffic areas.
- (3) The portion of trough area feeding from meter enclosure to the secondary of transformer should be free of load conduits. These conduits should be located as shown in drawings above.

REFERENCES

- (1) See DS-7-16.10 Guard Post
- (2) See Section DS-7-__ for Individual Pad Details
- (3) See MS-2-7.0 Three-Phase Thirteen-Terminal Socket for CT Meter
- (6) See MS-7-2.0 Working Space Required for Meter Enclosure

Maintenance Only