

NOTES

- (1) Transformers can be a fire hazard since they contain flammable oil.
- (2) The above dimensions allow bayonet operation.
- (3) Permanent obstruction in the single hatched working space shall not block access to the transformer.
- (4) Guard posts are required in traffic area.


REFERENCES

- (1) See Section 7 for Appropriate Concrete Pad
- (2) See DS-7-16.10 Guard Post
- (3) See DS-7-17.0 Working Space and Fire Safety Requirements Supplement

Fire Wall

Single-phase transformer or three-phase transformer or combination three-phase transformer and metering enclosure for commercial installation

Working Space



Three Hour Masonry Firewall



Minimum Working Space and Fire Safety Requirements for Transformers

DS-7-16.12