



Allowable Uses

- Permanent 120/240 Overhead Services
- Permanent Customer Owned Underground Services
- Temporary Overhead and Underground Service

NOTES

- (1) Socket to be Underwriters Laboratory (UL) listed.
- (2) Connections for terminating service conductors shall be the lay-in type.
- (3) Service conduit to enter at point "A"
- (4) No load conduits or load conductors in shaded area from front to back.
- (5) PNM will make line terminations on underground permanent residential services only.
- (6) Replace of the existing failed "Underground Meter Socket" ONLY.
- (7) Customer must fill an application with PNM to replace the bad meter socket.
- (8) Permit and inspection tag must be provided before reconnect.
- (9) PNM does not permit a trough ahead of meter socket.

REFERENCES

- (1) See DS-4-5.0 Underground Service Entrance System
- (2) See DM-4-11.0 Maximum Available Fault Current

Approved Equipment		
Manufacturer	Item	Mfg Part #
Eaton	200A UG Ringless Socket	UTRS223ACH
Eaton	200A UG Ringless Socket	UTRS223CCH
Durham	200A UG Ringless Socket	UTRS220A
Durham	200A UG Ringless Socket	UTRS223ACH
Milbank	200A UG Ringless Socket	U1980-O
Milbank	200A UG Ringless Socket	U3850-O-TG

For ease of checking service without interruption, PNM will no longer allow ring meter sockets as of 12/01/2013.