



NOTES

- (1) Socket to be Underwriters Laboratory (UL) listed.
- (2) Meter shall be 4' - 5' 6" from finished grade.
- (3) Metering and instrument cabinets shall not be used to house Customer-owned equipment, such as distribution panels or other equipment, nor used as a junction box/trough for the distribution of circuits.
- (4) Customer building numbers must be permanently painted on proper meter panels.

Approved Equipment		
Manufacturer	Item	Mtg Part #
Milbank	3 Phase 13 T Ringless Trans Socket	U2161-XT
Milbank	1 Phase 6 T Ringless Trans Socket	U2228-XT

For ease of checking service without interruption, PNM will no longer allow ring meter sockets as of 12/01/2013.

Ringless Trans Socket

MS-2-8.0