



NOTES

- (1) Socket to be Underwriters Laboratory (UL) listed.
- (2) Socket shall be 20A class only.
- (3) Meter shall be 4' - 5' 6" from finished grade.
- (4) Socket shall have two separate covers for meter and test switch compartments.
- (5) Latching bottom compartment shall lock both covers.
- (6) Metering and instrument cabinets shall not be used to house Customer-owned equipment, such as distribution panels or other equipment, nor used as a junction box/trough for the distribution of circuits.
- (7) Customer building numbers must be permanently painted on proper meter panels.

Approved Equipment		
Manufacturer	Item	Mfg Part #
Brooks Utility Products	20A 13T Ringless Socket	601U3060C13
Cutler Hammer	20A 13T Ringless Socket	98378513CH
Eaton	20A 13T Ringless Socket	USTS132CCH
Eaton	20A 13T Ringless Socket	98378513
Milbank	20A 13T Ringless Socket	UC3423-XL
Siemens	20A 13T Ringless Socket	9837-8543

For ease of checking service without interruption, PNM will no longer allow ring meter sockets as of 12/01/2013.