



NOTES

- (1) Four 5/8 x 18" anchor bolts recommended.
- (2) Recommend 3" minimum foundation extension all sides.
Recommend 6" minimum depth.
- (3) Minimum 36" clearance required per NEC 110-16 typical front/back.
- (4) Service ONLY Three-wire 240V

REFERENCES

- (1) See DM-4-11.0 Maximum Available Fault Currents

Approved Equipment		
Manufacturer	Item	Mfg Part #
Milbank	Ringless Pedestal with Bypass	CP3B51115A22
TESCO	Ringless Pedestal with Bypass	27000

For ease of checking service without interruption, PNM will no longer allow ring meter sockets as of 12/01/2013.