

PUBLIC SERVICE COMPANY OF NEW MEXICO
2nd REVISED RULE 14
CANCELLING 1ST REVISED RULE 14

TEMPORARY SERVICE, STANDBY SERVICE, AND SPECIAL SERVICES

PAGE 1 OF 2

- A. Whenever the service requested by the Customer is temporary, special, or emergency, a written application or contract will be required which will cover the period of service, character of service, and extra charges for the installation and removal of the required service connections, transformers, and accessory equipment, together with all material, labor, and other expense incidental thereto. This is a one-time charge and is nonrefundable. x
- B. The rate to be charged for such service will be in accordance with the Company's existing applicable schedules. Service for specialized usage shall be considered as a special case when not covered by specific filed rate schedules for the specialized usage. x
- C. When temporary single-phase or three-phase service is installed, a charge will be made, pursuant to Rate Schedule 16, for each such temporary service if no more than an overhead service drop is required. If more than an overhead service drop is required for such temporary connections, an additional connection charge equal to the cost that is in excess of the cost of the service drop shall be paid by the customer. This is a one-time charge and is nonrefundable. All such temporary service drops shall be supported on a pole, post, or other supporting member approved by the Company but which shall be furnished and installed by the Customer. For such temporary service, the applicable rate shall apply. x
- D. Service to mobile home parks will be provided under the following general policy:
1. Service to the permanent office building, rest rooms, bath-house, laundry facilities, outside lighting, etc., necessary to the general operation of the mobile home park, will be considered Commercial Service and will be billed under the applicable Commercial Rate.
 2. Service to individual mobile homes will be billed under the Residential Rate when individual meter bases are provided which comply with existing PNM Distribution Standards, Rules and Regulations, and are approved by the authority having jurisdiction. x
 3. Multiple services to one parcel will be ganged at the discretion of the PNM engineering department or the second service can be no more than 10 feet from PNM equipment (transformer or secondary pedestal). x
 4. The Customer may elect to have only one meter for the entire park or group of mobile homes, incorporating a flat rate for electrical service in the rental fee, in which case billing will be under the applicable Commercial rate. x
 5. No submetering or resale of electric power will be permitted

Advice Notice No. 632
/s/Henry Monroy
Henry Monroy
Vice President, PNM Regulatory

EFFECTIVE

March 7, 2025

Replaced by NMPRC

By: Rule No. 17.1.210

GCG#533437

- E. The Customer shall install only such motors or other apparatus or appliances as are suitable for operation with the character of the service supplied by the Company and which are not detrimental to that service. Further, the electric power must not be used in such a manner as to cause abnormal voltage fluctuations or disturbances to the Company's distribution system. The Company may require the installation of approved starting current load limiting devices on motors of 3 horsepower or more. Upper limits of inrush starting current tolerances will be determined by the Company.
- F. All neon, fluorescent, or other types of lighting equipment of similar low power factor, requiring a total of 200 watts or more, shall be designed or equipped to operate at a power factor of not less than 95 percent lagging or leading.
- G. Installations such as welders, which cause abnormal load an voltage fluctuations, shall be designed or equipped to operate at a power factor of not less than 90 percent, and the installation shall be made so the operation of such installations will not be detrimental to the service furnished other customers.
- II. When the customer furnishes the necessary complete substation equipment to take service at primary service voltage, such equipment shall be maintained by the Customer and shall include the necessary transformers, structures, controls, and protective equipment. The quality and construction of such equipment shall be subject to approval by the Company and meet the code or codes applicable to the installation. Protective equipment furnished by the Customer shall be in compliance with Rule 16.

EFFECTIVE

March 7, 2025

Replaced by NMPRC

By: Rule No. 17.1.210

Advice Notice No. 632

/s/Henry Monroy

Henry Monroy

Vice President, PNM Regulatory

GCG#533437