



NOTES

- (1) Transformers can be a fire hazard since they contain flammable oil.
- (2) The above dimensions allow bayonet operation.
- (3) Permanent obstruction in the single hatched working space shall not block access to the transformer. No construction above working space allowed and transformer shall not be inside any structure including parking garages.
- (4) Guard posts are required in traffic area.

REFERENCES

- (1) See Section 7 for Appropriate Concrete Pad
- (2) See DS-7-16.10 Guard Post
- (3) See DS-7-17.0 Working Space and Fire Safety Requirements Supplement

Fire Wall

Single-phase transformer or three-phase transformer or combination three-phase transformer and metering enclosure for commercial installation

