



NOTES

- (1) Disconnect Label: Red etched placard on switch must identify type of COGEN and contain the language "Generation Disconnect", i. e. "PV Generation Disconnect" or "Energy Storage Disconnect" or "Wind generation Disconnect."
- (2) One-Line Electrical and Site Map: Weatherproof drawings located within 2' of billing meter. See table for approved methods.

APPROVED WEATHERPROOF METHODS FOR DRAWINGS:
Etched placard, legible and permanently fixed
Document canister by Agri Supply or equivalent
Mail box